

# LICENCE

No. 19652 replaces No.16321

Issued to:

Applicant:

**BSI S.A**

**Rue Georges Stephenson**

**Zone Industrielle C**

**7180 Seneffe**

**Belgium**

Licensee:

**BSI S.A**

**rue Georges Stephenson**

**Zone Industrielle C**

**7180 SENEFFE**

**Belgium**



Product : conduit systems for cable management

Trade name(s) : ARVA, BSI, SCALA

Type(s)/model(s) : Conduits M16, M20, M25, M32, M40 and M50 mm

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 82

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 14/09/2015



ir. C. Lana,

Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



**SGS Belgium NV-Division SGS CEBEC**  
**Business Riverside Park**  
**Bld Internationalelaan 55 Build. D**  
**B-1070 Brussels**  
**Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36**

This certificate is issued by the company under its General Conditions for Certification Services accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

Product	:	conduit systems for cable management
Trade name(s)	:	ARVA, BSI, SCALA
Type(s)/Model(s)	:	Conduits M16, M20, M25, M32, M40 and M50 mm
type of conduit (1)	:	non-metallic
type of conduit (2)	:	classification 3-2-3-1
type of conduit (3)	:	plain
method of connection	:	non-threadable
resistance to compression	:	medium
resistance to impact	:	light
resistance to bending	:	rigid
lower temperature range	:	-15°C
upper maximum temperature range	:	+60°C
electrical characteristics	:	with electrical insulating
resistance to flame propagation	:	non-flame propagation
colour(s)	:	RAL 7035, RAL 7037, RAL 7016 RAL 2003, RAL 2011, RAL 6005 RAL 5012, RAL 5015, RAL 9005

## TESTS

### Test requirements

NBN EN 60423 based on EN 60423:1994  
NBN EN 61386-1 based on EN 61386-1:2008  
NBN EN 61386-21 based on EN 61386-21:2004 + A11:2011

### Test results

The test results are laid down in certification file ref.621403/01

### Remarks

This certificate is based on TRF No 582003.01

### Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 14/09/2015

Department Manager,  
Product Certification :

Certification Manager :

*Luigi Zanutto* 2015-09-14



**FACTORY LOCATION(S)**

BSI S.A  
rue Georges Stephenson  
Zone Industrielle C  
7180 SENEFFE  
Belgium